

# Citizens Guide for Maintenance of Stormwater Control Measures



Montgomery County Building & Codes  
Stormwater Program  
350 Pageant Lane, Suite 309  
Clarksville, TN 37040  
Phone: (931) 648-5718  
Fax: (931) 553-5121



## Table of Contents

Section	Page
1. Purpose.....	3
2. What is stormwater Runoff?.....	3
3. How Montgomery County is Managing Stormwater.....	3
4. Importance of Stormwater Control Measures.....	4
5. Requirements and Responsibilities.....	5
6. Maintenance Plans.....	6
7. Easements.....	9
8. Who Should Perform Maintenance?.....	9
9. Common Stormwater Control Measures.....	10
10. Basic Maintenance.....	13
11. Poorly Maintained Stormwater Control Measures.....	15
12. Good Housekeeping Practices.....	17
13. Stormwater SCM Maintenance Guidelines.....	18
Appendix 1 - Inspection Checklists and Maintenance Guidelines.....	19
Appendix 2 – Contacts.....	39
Appendix 3 – References and Credits.....	40
Appendix 4 – Stormwater Maintenance Agreement.....	42

## **1. Purpose**

This guide has been prepared to:

- help you identify stormwater systems in your neighborhood,
- describe stormwater inspection and maintenance requirements,
- provide inspection and maintenance guidelines for your stormwater systems, and
- Identify resources available to provide assistance.

## **2. What is Stormwater?**

Stormwater is the runoff that flows over land during and immediately after a rain event. When stormwater flows over urbanized areas, pollutants such as petroleum products, antifreeze, fertilizers, pesticides, animal wastes, and trash are carried to local streams and rivers. These pollutants can stay in the environment for long periods of time. Stormwater runoff is the most common cause of water pollution

## **3. How Montgomery County is Managing Stormwater**

On February 12, 2024, the Montgomery County Commission adopted The Montgomery County Stormwater Resolution (24-2-2). This resolution set the County Stormwater Regulations for:

- Construction site stormwater runoff control in areas of new development and re-development
- Post-construction stormwater management in areas of new development and re-development

- An illicit discharge detection and elimination (IDDE) program
- County operation pollution prevention and good housekeeping procedures
- Public education and outreach on stormwater impacts
- Public Involvement / Participation

It is important to note that effective stormwater management is a partnership between landowners, Homeowner Associations and the Montgomery County Stormwater Program.

#### **4. Importance of Stormwater Control Measures**

Stormwater Control Measures (SCMs) are schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the discharge of pollutants to surface waters or groundwater.

Stormwater Control Measures include treatment systems, operating procedures, and practices to control pollution from area runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.

Common treatment systems include stormwater detention ponds, vegetated swales, water quality buffers, Bioretention areas and porous pavements. Each of these SCMs are designed to filter or separate pollutants from stormwater runoff. In some cases, SCMs are designed to also protect property from flooding.

All SCMs require regular maintenance. For example, ponds become repositories for sediment, litter and oil. Vegetated areas used to filter out pollutants can become overrun with invasive, non-native plants that prevent long rooted native vegetation from flourishing. Eroded slopes and banks increase the amount of sediment in our waterways, adversely affecting fish and plant life.

It is important to remember, routine inspections and maintenance is vital to ensure stormwater SCMS remain effective and function as designed. These SCMs, properly maintained reduces flooding potential and improves water quality.

## 5. Requirements and Responsibilities

Proper maintenance of stormwater facilities and Stormwater Control Measures is one of the most important factors in long term performance and effectiveness of a stormwater management plan. Montgomery County requires property owners or homeowners associations (HOA) to properly maintain the stormwater system and SCMs associated with private property.

Routine inspection and maintenance of SCMs protects you, the homeowner, from property damage caused by flooding. In addition, the costs associated with regular maintenance are far less than those required to replace a failed system.

Homeowners and HOAs are bound by the requirements set forth by Section 6 of the Montgomery County Stormwater Regulations. The Stormwater Regulations state that property owners have the responsibility to ensure that stormwater SCMs are maintained as designed. These requirements are also stipulated in the Stormwater Maintenance Agreement associated with development since 2008.

The Stormwater Inspection & Maintenance Agreement (SWI&MA) is recorded with the property deed, and is a covenant to maintain permanent stormwater facilities and SCMs. This agreement assigns responsibility for SCM maintenance to the property owner(s).

If your development or facility does not have a SWMA, call the Montgomery County Building & Codes Department at 931-648-5718 for assistance in determining your responsibilities.

All homeowners and HOAs should be familiar with the requirements set forth in your SWI&MA. Homeowners should also maintain inspection and maintenance records. All SCMs and other stormwater facilities must be inspected by a licensed engineer or landscape architect every five years. *Property owners are still required to inspect SCMs and stormwater facilities periodically, and document those inspections and any maintenance performed.*

### Who's Responsible?

<b>Homeowners must:</b>	<b>Montgomery County must:</b>
Inspect SCMs in accordance with maintenance agreement or as set forth in the Stormwater Regulations	Enforce provisions of maintenance agreements and Stormwater Regulations
Provide necessary maintenance	Periodically inspect SCMs on private property
Keep inspection and maintenance records	Issue Notices of Violation if required and ensure corrective actions are taken
Ensure SCMs are inspected by a licensed engineer or landscape architect every 5 years	Maintain stormwater structures in the public right-of-ways

Drainage problems in your neighborhood can be prevented by regular SCM inspection and maintenance. If a problem arises however, it may be necessary to contact a professional with expertise in drainage engineering.

## 6. Maintenance Plans

A maintenance plan should be developed to ensure responsibilities are assigned, inspection frequencies established, and efforts documented.

### Regulatory and Legal Requirements

SCMs on private property must be maintained by the property owner. Consult your maintenance plan to determine inspection and maintenance requirements. If you don't have a maintenance plan, refer to the Montgomery County Stormwater Resolution. It is important to understand the legal implications of failing to maintain drainage systems on your property or in your neighborhood.

## SCM Inventory

Use the plat to locate your SCMs and associated easements. Walk the site and note the condition of each. If the site contains older or complex SCMs, you may want to contact a professional with expertise in stormwater drainage for assistance.

## Responsibilities

Designate a responsible person to ensure SCMs are inspected on a routine basis and maintenance is performed as required. Choose a person interested in the task who is detail-oriented, reliable, and willing to train others. Document inspector responsibilities as part of the maintenance plan. The services of a professional engineer or landscape architect may be required, depending on the condition and complexity of your stormwater systems.

## Inspection Frequency

Your plan should specify an inspection frequency for each SCM. This will be determined by SCM complexity and the requirements set forth in the maintenance agreements. If a maintenance agreement doesn't exist for your neighborhood, follow the guidelines set forth in *Appendix 1*.

## Inspection Checklists & Maintenance Activities

Inspection checklists, specific for each SCM, are important to ensure thoroughness and for documentation purposes. Inspection checklists are included in *Appendix 1*. Maintenance activities for each SCM are also found in *Appendix 1*.

## Record Keeping

The plan should specify how completed inspection checklists and SCM maintenance records will be retained. Also include your neighborhood site map, which identifies and locates all stormwater SCMs. (The map can be obtained from your operation and maintenance plan or from Montgomery County Stormwater Management. See *Appendix A2*.) Your records should include identification

numbers for each SCM, SCM type and location, data from previous inspections, special maintenance needs and photos of your SCMs.

### Resource Allocation

Identify costs and funding mechanisms. How will funds be collected and distributed? Work with drainage professionals to estimate the costs of complex maintenance needs.

### Education

Use HOA meetings or newsletters to ensure homeowners, particularly those living adjacent to a SCM, understand the function of their stormwater systems. For example, vegetated buffers shouldn't be mowed to make them more aesthetically pleasing, and ponds should be kept free of invasive vegetation. Review the simple and effective steps provided in *Good Housekeeping Practices* (Section 12) with all homeowners.

### Annual Program Reviews

Review your inspection and maintenance program on an annual basis.

- Are inspection and maintenance activities being conducted at the appropriate frequency and documented as required?
- Are the checklists appropriate for your SCMs? Is modification required?
- Are you satisfied with the services of your landscaping or inspection and maintenance contractors?
- Are appropriate resources allocated to the program? Do you need to adjust HOA fees?



## 7. Easements

Easements are required for SCMs located on your property and in your neighborhood. These legally binding agreements, noted on your plat, allow Montgomery County to access stormwater SCMs. Property owners are required to maintain easements and associated access points.

Do not erect structures that prevent access or obstruct the flow of water, such as fences, walls, sheds, or buildings. Avoid planting woody vegetation within the easement area. Be aware that maintenance activities may require removal of structures, such as fencing, paving, or woody vegetation at the homeowner's expense.

## 8. Who Should Perform Maintenance?

Consider cost, safety and effectiveness when determining who should perform SCM maintenance. Routine tasks, such as litter removal and landscaping, can be carried out by homeowners.

For more difficult work (mowing or working on sloped embankments, stabilizing eroded areas, removing sediment from ponds, or repairing/cleaning inlets and outlets) consider using the services of a professional landscaper.

Extensive maintenance work may require the services of a professional engineer or landscape architect. Erosion, sinkholes, a rusty, broken, or crushed pipe, odor, or algae blooms are all clear indications to call a consulting engineer.

***Montgomery County's Stormwater Regulations require that structural SCMs be inspected by an engineer or landscape architect at least once every 5 years. This is addition to the routine inspection and maintenance that is required by the landowner.***

When working with lawn care companies for simple maintenance, be sure to communicate:

- That SCM facilities are water quality devices;

- That different mowing practices may be required (mowing at a higher level, not as frequently, or not at all in buffer areas);
- The need to keep the SCM facility clear of grass clippings and leaf piles;
- The need to use minimal or no pesticides and to have a policy of not applying chemicals when there is rain in the forecast.

## 9. Common Stormwater Control Measures

This section describes the most common structural SCMs found in Montgomery County neighborhoods, and summarizes basic maintenance requirements. Homeowners are encouraged to use the inspection checklists and detailed maintenance guidelines provided in *Appendix 1*. These checklists, specific for each type of SCM, will help ensure the maintenance needs of each SCM are thoroughly addressed. They are also convenient for tracking and documenting your stormwater management efforts.

### Wet Retention Ponds

Wet ponds may appear to be natural ponds, but they are specially *designed* to control stormwater runoff volume and quality. Excess runoff is stored above a permanent pool of water and discharged at a controlled rate through an outlet. Water quality is controlled through pollutant settling and absorption.



## **Dry Detention Ponds**

Although dry ponds are sometimes viewed as a waste of space, they are specifically designed to collect and temporarily hold stormwater runoff. Montgomery County generally requires extended dry detention basins. In this case, settling rather than filtration is the pollutant removal mechanism.



## **Vegetated Swales**

Swales are open, channel-like systems used to convey stormwater runoff. Although swales may look like typical ditches, they are designed to slow water flow and absorb pollutants. They may be used to convey water to another SCM, such as a detention pond. Swales are often located along roadsides or parking lots.



## **Vegetated Buffers**

Buffers are areas of vegetation established adjacent to waterways to slow stormwater runoff, provide an area where runoff can permeate the soil, and filter pollutants.



## **Bioretention**

Bioretention areas, usually recessed, are landscaping features that use engineered soils and vegetation to capture, filter and store stormwater runoff.



### **Porous Pavement**

An alternative to traditional asphalt or concrete, porous pavement is a permeable pavement surface with a stone reservoir underneath. The reservoir temporarily stores surface runoff before infiltrating it into the soil, thereby providing some water quality treatment.



## **10. Basic Maintenance**

The basic maintenance guidelines that follow provide a glimpse of the efforts required to keep stormwater systems functioning properly. Homeowners are advised to use the checklists provided in *Appendix 1*, however, to ensure SCM specific maintenance needs are addressed. Note that it may be necessary to consult with a professional who has expertise in drainage engineering for repeated or complex problems.

### **Basic STORMWATER CONTROL MEASURES Maintenance**

- Remove debris from inlet/outlet structures.
- Thick and healthy native vegetation is desirable, but keep stormwater ponds free of invasive vegetation. Proper vegetation may be addressed in the maintenance plan, or refer to Appendix A2.
- Repair eroded slopes.
- Don't fill ponds or swales with dirt. Remove sediment from ponds when it becomes noticeable.
- Keep trash, debris and grass clippings out of swales and ponds and away from storm drains.
- Inspect SCMs following any major rain event.

### **Indicators for Maintenance**

Following are some common conditions that indicate a need for stormwater system maintenance.

#### **Erosion**

Finding the source of erosion and stabilizing it can improve the effectiveness of a wet basin or swale. Left unchecked, an erosion problem can necessitate dredging, replacement of an entire embankment or slope, or even an inlet structure. A prime cause of erosion is lack of deep-rooted vegetation that holds soil in place.

#### **Mosquitos**

Mosquito's breeding grounds can be created in shallow ponds of standing water. It is likely the infiltration capacity of the SCM needs to be increased, or sediment needs to be removed. An insect control option for larger wet basins is to maintain a stock of fish to feed on mosquito larvae. In addition, natural vegetated buffers can provide shelter for mosquito predators.

### **Algae Growth**

A healthy wet basin should require little maintenance. A good indicator of an unhealthy ecosystem is excessive algae growth. This could be caused by nutrients from fertilization practices by a landscape company or surrounding neighbors, upstream activities, or excess sediment.

*Without proper maintenance, any system will fail. Costs associated with STORMWATER CONTROL MEASURES repair can **far exceed** the cost of preventive maintenance.*

## **11. Poorly Maintained STORMWATER CONTROL MEASURES**

A clogged storm drain creates flooding problems by not allowing runoff water to drain properly. If clogged with trash, leachate from the trash can pollute the water.



Poorly vegetated swales can lead to erosion damage and property value loss. Water can be polluted by sediment released in the erosion process





Blocked inlets and area drains can result in area flooding.



## 12. Good Housekeeping Practices

- Dispose of household chemicals, paint, cleaning products, fertilizers, and pesticides properly. Pouring these hazardous substances down a storm drain, onto the ground or into a stream creates a danger to all the citizens of the county, as well as the environment. The Bi-County Solid Waste Management regularly sets collection dates and times for household hazardous waste. For more information call 931-648-5751.
- When using fertilizers, pesticides and herbicides, mixing instructions should be carefully followed. The application of these chemicals should follow manufacturer recommendations for safe use and should be based on actual need as determined by testing. Use the least toxic product possible for each application. Avoid over-application, application to impervious areas, or application to irrigated or automatically watered areas to prevent these products from washing into stormwater drains, groundwater or surface water. Never mix products to save time.
- Pet waste left on the ground gets carried away by stormwater, contributing harmful bacteria, parasites, and viruses to our rivers and streams. Please clean up after your pet.
- Vehicle fluids such as oil, gas, and antifreeze are the #1 surface water quality problems nationwide. All vehicle fluids are toxic and extremely harmful to the environment. Recycle used oil in a clean, sealed, plastic container.
- Yard waste such as grass clippings, tree trimmings, and leaves can be composted and used for fertilizer around the yard. Do not dump yard waste in a storm drain or store it where stormwater can wash it into the storm drain system.
- Street litter such as styrofoam, plastic, and paper can be kept out of our streams and rivers by keeping trash bins covered and by not littering.
- SWEEP! Hosing off pavements washes pollutants into storm drains that lead straight to the river.

### **13. STORMWATER CONTROL MEASURES MAINTENANCE GUIDELINES**

The required maintenance interval for stormwater Stormwater Control Measures (SCMs) are often dependent upon the degree of pollutant loading from a particular drainage basin. SCM maintenance can best be broken into three categories: **inspection, routine maintenance, and major maintenance.**

Though each SCM type has its own unique characteristics, **inspections** will generally consist of an assessment to assure its functionality and the general condition.

**Routine maintenance** will generally consist of trash and vegetation removal, unclogging of drains, minor sediment removal and exchange of filter media where applicable.

**Major maintenance** will be completed as required from inspections and generally consists of *significant reconstruction due to failures* in the SCM. Examples of major maintenance include dredging, excavation, removal of existing media, replacing fabric, replacing the under-drain, and reestablishment of vegetation.

The following schedule is offered as a guideline for performing *inspection and routine maintenance* for a range of SCM categories.

SCM	Inspection Frequency	Routine Maintenance Frequency
<b>Inspection Frequency key:</b> A = annual; M=monthly; S=after major storms; Q=Quarterly; SA=Semi Annually		
Bio-retention Systems	A, S	2 x /year
Cartridge or Module Media Filtration Structures	SA	1 – 2 x /year
Dry Pond	M	3 – 4 x /year
Dry Wells	A	1 x /year
Filter Strips or Swales	M	2 – 3 x /year
Green Roofs	SA; S	2 – 3 x /year
Hydrodynamic or Gravity Separators	SA	1 – 2 x /year
Infiltration Trenches	A; S	2 – 3 x /year
Permeable Pavement	A	2 – 3 x /year
Rainwater Gardens	SA; S	2 – 3 x /year
Rainwater Harvesting	SA; S	2 – 3 x /year
Sand Filter	Q first year; SA after	1 – 2 x/ year
Trash & Debris Screens	SA; S	2 – 3 x /year
Underground Storage Facilities	SA	1 x /year
Wetlands	SA	2 x /year
Wet Pond	Q	2 – 3 x /year
Headwalls	A	1x/ year
Injection Well	Q	3 – 4 x /year

All SCMs must be inspected and certified by a licensed engineer or landscape architect every 5 years. Questions about SCM maintenance and repair can be directed to the Office of the Stormwater Coordinator For more information and inspection sheets go to: <https://mcgtn.org/stormwater/best-practices>

## Appendix 1 – Inspection Checklists

## **Bioretention Inspections and Maintenance Checklist**

Site Name: \_\_\_\_\_ Owner Change since last inspection? Y N  
Location: \_\_\_\_\_

Owner Name: \_\_\_\_\_  
 Address \_\_\_\_\_ Phone Number \_\_\_\_\_  
 Site Status: \_\_\_\_\_  
 Date: \_\_\_\_\_ Time: \_\_\_\_\_ Site conditions: \_\_\_\_\_

*Inspection Frequency Key: A=annual (required); M=monthly (recommended); S=after major storms (recommended)*

Inspection Items	Inspection Frequency	Inspected? (Yes/No)	Maintenance Needed? (Yes/No)	Comments/Description
<b>Pre-Treatment Area</b>				
Area free of debris?	A/M			
Standing water longer than 24 hours after a storm event?	A/S			
Bare soil or erosion?	M/S			
Excessive landscape waste/yard clippings?	A/M			
<b>Inlet/Outlet Structures</b>				
Inlets provide stable conveyance into the facility?	A			
Evidence of erosion at or around inlet?	A			
If connected to extended detention, is outlet to pond functioning properly?	A			
Other	A			
<b>Basin</b>				
Adjacent area fully stabilized (no evidence of eroding material into Bioretention area)?	A			
Plant height not less than design ponding depth?	A			
Adequate media layer present?	A			
Plant composition according to approved plan?	A			
Grass height not more than 6 inches?	A/M			
Vegetation overgrown?	A			
Invasive species/weeds present?	A			
Dead vegetation or exposed soil present?	A			
Maintenance access to facility?	A			
Excessive trash/debris/sediment?	A			
Evidence of erosion?	A			

Evidence of standing water (Ponding, Noticeable Odors, Water Stains, Algae)?	A/M			
If underdrain system, is it broken or clogged?	A/M			
Overflow structure free of blockage and operating properly?	A			
Other	A			
<b>Hazards</b>				
Have there been complaints from residents?	A/M			
Public hazards noted?	A/M			
Mosquito proliferation?	A/M			
Is there encroachment on pervious area or easement by buildings or other structures?	A/S			

Inspector Comments: \_\_\_\_\_  
 \_\_\_\_\_

Overall Condition of Facility:  Acceptable  Unacceptable

If any of the above Inspection Items are checked "Yes" for "Maintenance Needed," list Maintenance actions and their completion dates below:

Maintenance Action Needed	Due Date

The next routine inspection is scheduled for approximately: \_\_\_\_\_  
 (Date)

Inspected by: (signature) \_\_\_\_\_  
 Inspected by: (printed) \_\_\_\_\_

**Buffer Inspections and Maintenance Checklist**

Site Name: \_\_\_\_\_ Owner Change since last inspection? Y N  
 Location: \_\_\_\_\_  
 Owner Name: \_\_\_\_\_

Address \_\_\_\_\_ Phone Number \_\_\_\_\_  
 Site Status: \_\_\_\_\_  
 Date: \_\_\_\_\_ Time: \_\_\_\_\_ Site conditions: \_\_\_\_\_

*Inspection Frequency Key: A=annual (required); M=monthly (recommended); S=after major storms (recommended)*

Inspection Items	Inspection Frequency	Inspected? (Yes/No)	Maintenance Needed? (Yes/No)	Comments/Description
<b>Vegetation</b>				
Surrounding area fully stabilized? (no evidence of eroding material into buffer)	A/M			
Undisturbed?	A/M			
Vegetation healthy?	A/M			

Inspector Comments: \_\_\_\_\_  
 \_\_\_\_\_

**Overall Condition of Facility:**  Acceptable  Unacceptable

If any of the above Inspection Items are checked "Yes" for "Maintenance Needed," list Maintenance actions and their completion dates below:

Maintenance Action Needed	Due Date

The next routine inspection is scheduled for approximately: \_\_\_\_\_  
 (Date)

**Inspected by: (signature)** \_\_\_\_\_  
**Inspected by: (printed)** \_\_\_\_\_

**Constructed Wetlands Inspection and Maintenance Checklist**

Site Name: \_\_\_\_\_ Owner Change since last inspection? Y N  
 Location: \_\_\_\_\_  
 Owner Name: \_\_\_\_\_  
 Address \_\_\_\_\_ Phone Number \_\_\_\_\_

Site Status: \_\_\_\_\_

Date: \_\_\_\_\_ Time: \_\_\_\_\_ Site conditions: \_\_\_\_\_

Constructed Wetland Type:                      ED Wetland                       Pocket Wetland                       Wetland

*Inspection Frequency Key: A=annual (required); M=monthly (recommended); S=after major storms (recommended)*

Inspection Items	Inspection Frequency	Inspected? (Yes/No)	Maintenance Needed? (Yes/No)	Comments/Description
<b>Embankment and Emergency Spillway</b>				
Vegetation healthy?	A/S			
Erosion on embankment?	A/S			
Animal burrows in embankment?	A/S			
Cracking, sliding, bulging of dam?	A/S			
Drains blocked or not functioning?	A/S			
Leaks or seeps on embankment?	A/S			
Slope protection failure functional?	A/S			
Emergency spillway obstructed?	A/S			
Erosion in/around emergency spillway?	A/S			
Other (describe)	A/S			
<b>Riser and Principal Spillway</b>				(Describe type: concrete pipe, slotted weir, channel, etc.)
Low-flow orifice functional?	A/S			
Trash rack (Debris removal needed? Corrosion noted?)	A/S			
Sediment buildup in riser?	A			
Concrete/masonry condition (Cracks or displacement? Spalling?)	A			
Metal pipe in good condition?	A			
Control valve operation?	A			
Pond drain valve operation?	A			
Outfall channels function, not eroding?	A			
Other (describe)	A			
<b>Sediment Forebays</b>				
Sedimentation description				
Sediment cleanout needed (over 50 percent full)?	A/S			
<b>Constructed Wetland Ponding Areas</b>				



Wetland vegetation present and healthy?	<i>M</i>			
Vegetation removal needed?	<i>A/M</i>			
Floatable debris removal needed?	<i>A/M</i>			
Visible pollution?	<i>A/M</i>			
Shoreline problem?	<i>A/M</i>			
Erosion at outfalls into pond?	<i>A/M</i>			
Headwalls and end walls in good condition?	<i>A/M</i>			
Encroachment into pond or easement area?	<i>A/M</i>			
<b>Hazards</b>				
Have there been complaints from residents?	<i>A/M</i>			
Public hazards noted?	<i>A/M</i>			

Inspector Comments: \_\_\_\_\_  
 \_\_\_\_\_

Overall Condition of Facility:  Acceptable  Unacceptable

If any of the above Inspection Items are checked "Yes" for "Maintenance Needed," list Maintenance actions and their completion dates below:

Maintenance Action Needed	Due Date

The next routine inspection is scheduled for approximately: \_\_\_\_\_  
 (Date)

Inspected by: (signature) \_\_\_\_\_

Inspected by: (printed) \_\_\_\_\_

### Filter Strips Inspections and Maintenance Checklist

Site Name: \_\_\_\_\_ Owner Change since last inspection? Y N

Location: \_\_\_\_\_

Owner Name: \_\_\_\_\_

Address \_\_\_\_\_ Phone Number \_\_\_\_\_

Site Status: \_\_\_\_\_

Date: \_\_\_\_\_ Time: \_\_\_\_\_ Site conditions: \_\_\_\_\_

*Inspection Frequency Key: A=annual (required); M=monthly (recommended); S=after major storms (recommended)*

Inspection Items	Inspection Frequency	Inspected? (Yes/No)	Maintenance Needed (Yes/No)	Comments/Description
<b>Debris Removal</b>				
Facility and adjacent area free of debris?	A/M			
Inlets and outlets free of debris?	A/M			
Any dumping of yard wastes into facility?				
Litter (branches) removed?	A/M			
<b>Vegetation</b>				
Surrounding area fully stabilized? (no evidence of eroding material into swale, channel or filter strip)	A/M			
Grass mowed?	A/M			
Plant height not less than design water depth?	A/M			
Fertilized per specifications?	A/M			
Plan composition according to approved plan?	A/M			
Unauthorized or inappropriate plantings?	A			
Plants healthy? (no diseased or dying vegetation)	A/M			
Evidence of plants stressed from inadequate watering?	A/M			
<b>Filtration Capacity</b>				
Clogging from oil or grease?	A/M			
Facility dewater between storms?	A/M			
<b>Check dams and energy dissipaters/sumps</b>				
Any evidence of sedimentation build up	A/S			
Are sumps greater than 50% full of sediment?	A/S			
Any evidence of erosion and downstream toe of drop structures?	A/S			
<b>Sediment Deposition</b>				
Swale clean of sediments	A			
Sediment not > 20% of swale design depth	A			
<b>Outlet/Overflow Spillway</b>				

In good condition?	A			
Any evidence of erosion?	A			
Any evidence of blockages?	A			
<b>Has facility been filled or blocked inappropriately?</b>	A			

Inspector Comments: \_\_\_\_\_

\_\_\_\_\_

Overall Condition of Facility:  Acceptable  Unacceptable

If any of the above Inspection Items are checked "Yes" for "Maintenance Needed," list Maintenance actions and their completion dates below:

Maintenance Action Needed	Due Date

The next routine inspection is scheduled for approximately: \_\_\_\_\_  
(Date)

Inspected by: (signature) \_\_\_\_\_

Inspected by: (printed) \_\_\_\_\_

### Grass Channel Inspections and Maintenance Checklist

Site Name: \_\_\_\_\_ Owner Change since last inspection? Y N

Location: \_\_\_\_\_

Owner Name: \_\_\_\_\_

Address \_\_\_\_\_ Phone Number \_\_\_\_\_

Site Status: \_\_\_\_\_

Date: \_\_\_\_\_ Time: \_\_\_\_\_ Site conditions: \_\_\_\_\_

Inspection Frequency Key: A=annual (required); M=monthly (recommended); S=after major storms (recommended)

Inspection Items	Inspection Frequency	Inspected? (Yes/No)	Maintenance Needed? (Yes/No)	Comments/Description
<b>Debris Removal</b>				
Facility and adjacent area free of debris?	A/M			
Inlets and outlets free of debris?	A/M			
Any dumping of yard wastes into facility?	A/M			
Litter (branches) removed?	A/M			
<b>Vegetation</b>				
Surrounding area fully stabilized? (no evidence of eroding material into swale, channel or filter strip)	A/M			
Grass mowed?	A/M			
Grass height not less than 3 to 4 inches?	A/M			
Fertilized per specifications?	A/M			
Grasses planted according to approved plan?	A/M			
Unauthorized or inappropriate plantings?	A			
Grasses healthy? (no diseased or dying vegetation)	A/M			
Evidence of grasses stressed from inadequate watering?	A/M			
<b>Filtration Capacity</b>				
Clogging from oil or grease?	A/M			
Facility dewater between storms?	A/M			
<b>Check dams and energy dissipaters/sumps</b>				
Any evidence of sedimentation buildup?	A/S			
Are sumps greater than 50% full of sediment?	A/S			
Any evidence of erosion and downstream toe of drop structures?	A/S			
Any trash or blockages at weep holes?	A/S			
<b>Sediment Deposition</b>				
Swale clean of sediments?	A			
Sediment not > 25% of swale design depth?	A			

<b>Outlet/Overflow Spillway</b>				
In good condition?	A			
Any evidence of erosion?	A			
Any evidence of blockages?	A			
Has facility been filled or blocked inappropriately?	A			
<b>Hazards</b>				
Have there been complaints from residents?	A/M			
Public hazards noted?	A/M			
Maintenance accesses free of hazards and fully operational?	A/M			

Inspector Comments: \_\_\_\_\_

**Overall Condition of Facility:**  Acceptable  Unacceptable

If any of the above Inspection Items are checked "Yes" for "Maintenance Needed," list Maintenance actions and their completion dates below:

<b>Maintenance Action Needed</b>	<b>Due Date</b>

The next routine inspection is scheduled for approximately: \_\_\_\_\_  
(Date)

**Inspected by: (signature)** \_\_\_\_\_

**Inspected by: (printed)** \_\_\_\_\_

### **Infiltration Trench Inspections and Maintenance Checklist**

Site Name: \_\_\_\_\_ Owner Change since last inspection? Y N

Location: \_\_\_\_\_

Owner Name: \_\_\_\_\_

Address \_\_\_\_\_ Phone Number \_\_\_\_\_

Site Status: \_\_\_\_\_

Date: \_\_\_\_\_ Time: \_\_\_\_\_ Site conditions: \_\_\_\_\_

Inspection Frequency Key: A=annual (required); M=monthly (recommended); S=after major storms (recommended)

Inspection Items	Inspection Frequency	Inspected? (Yes/No)	Maintenance Needed? (Yes/No)	Comments/Description
<b>Debris Removal</b>				
Trench surface clear of debris?	A/M			
Contributing area free of debris?	A/M			
Inlets/Inflow pipes free of debris?	A/M			
Overflow spillway clear of debris?	A/M			
<b>Vegetation</b>				
Mowing done when necessary?	A/M			
Unauthorized or inappropriate plantings?	A			
Fertilized per specification?	A/M			
Evidence of erosion?	A/M			
Contributing drainage area stabilized?	A/M			
Trees growing in the trench?	A			
<b>Dewatering</b>				
Trench dewatered between storms?	A/M			
<b>Sediment traps, Forebays, or Pretreatment Swales</b>				
Adequately trapping sediment?	A			
Structural damage?	A			
Greater than 50% of original storage volume remaining?	A			
<b>Sediment removal of trench</b>				
Any evidence of sedimentation in trench?	A			
Are pea gravel/topsoil and top surface filter fabric functioning properly?	A/M			
Does sediment accumulation currently require removal?	A			
<b>Inlets</b>				
Good condition (no need for repair)?	A			
Evidence of erosion?	A			
<b>Outlets/overflow spillway</b>				
Good condition (no need for repair)?	A			
Evidence of erosion?	A			

<b>Aggregate repairs</b>				
Surface of aggregate clean?	A			
Top layer of stone in need of replacement?	A			
Trench in need of rehabilitation?	A			
<b>Observation wells</b>				
Evidence of clogging/failure to percolate? (Should percolate within 3 days.)	A/M			
Has drawdown rate been measured at observation well and is well capped?	A			
<b>Hazards</b>				
Have there been complaints from residents?	A/M			
Public hazards noted?	A/M			

Inspector Comments: \_\_\_\_\_  
 \_\_\_\_\_

**Overall Condition of Facility:**  Acceptable  Unacceptable

If any of the above Inspection Items are checked "Yes" for "Maintenance Needed," list Maintenance actions and their completion dates below:

<b>Maintenance Action Needed</b>	<b>Due Date</b>

The next routine inspection is scheduled for approximately: \_\_\_\_\_  
 (Date)

**Inspected by: (signature)** \_\_\_\_\_

**Inspected by: (printed)** \_\_\_\_\_

### **Permeable Pavement Inspection and Maintenance Checklist**

Site Name: \_\_\_\_\_ Owner Change since last inspection? Y N

Location: \_\_\_\_\_

Owner Name: \_\_\_\_\_

Address \_\_\_\_\_ Phone Number \_\_\_\_\_

Site Status: \_\_\_\_\_

Date: \_\_\_\_\_ Time: \_\_\_\_\_ Site conditions: \_\_\_\_\_

\*\*\*\*\*Conduct maintenance inspection in the spring of each year.

Pavement Type: Pervious Concrete/Asphalt  Modular Pavers  Grass/Gravel Pavers

*Inspection Frequency Key: A=annual (required); M=monthly (recommended); S=after major storms (recommended)*

Inspection Items	Inspection Frequency	Inspected? (Yes/No)	Maintenance Needed? (Yes/No)	Comments/Description
<b>Pavement Area</b>				
Pavement area free of debris?	<i>A/M</i>			
Staining or sediment?	<i>A/M</i>			
Inlets and outlets unobstructed and sediment free?	<i>A/M</i>			
All contributing drainage area free of erosion and sources of sediment?	<i>A/M</i>			
Water standing after a storm event?	<i>S</i>			
Any evidence of clogged pores that require vacuum-sweeping?	<i>A/M</i>			
Has area been vacuum swept in the past 12 months?	<i>A/M</i>			
Access to pervious pavement (egress and ingress routes) safe and efficient?	<i>A/M</i>			
Has drawdown rate been measured at observation well and is well capped?	<i>A</i>			
Structural integrity of the pavement intact? Look for deterioration such as: slumping, cracking, spalling, or broken pavers.	<i>A/M</i>			
<b>Grass Pavers</b>				
Adjacent area fully stabilized (no evidence of eroding material into or from pervious pavement area)?	<i>A</i>			
Any noticeable irrigation needs?	<i>A/M</i>			
Fallen leaves/plant debris collecting in paving area?	<i>A/M</i>			
Grass height over 4 inches?	<i>A/M</i>			
Vegetation health affected by oil/grease from vehicles?	<i>A</i>			
Other	<i>A</i>			
<b>Hazards</b>				
Obstructions or debris affecting overflows/emergency spillways?	<i>A/M</i>			



Load-bearing capability of pavement intact?	A/M			
---	-----	--	--	--

Inspector Comments: \_\_\_\_\_  
 \_\_\_\_\_

**Overall Condition of Facility:**  Acceptable  Unacceptable

If any of the above Inspection Items are checked "Yes" for "Maintenance Needed," list Maintenance actions and their completion dates below:

Maintenance Action Needed	Due Date

The next routine inspection is scheduled for approximately: \_\_\_\_\_  
 (Date)

**Inspected by: (signature)** \_\_\_\_\_

**Inspected by: (printed)** \_\_\_\_\_

### Proprietary SCM Inspections and Maintenance Checklist

Site Name: \_\_\_\_\_ Owner Change since last inspection? Y N  
 Location: \_\_\_\_\_  
 Owner Name: \_\_\_\_\_  
 Address \_\_\_\_\_ Phone Number \_\_\_\_\_  
 Site Status: \_\_\_\_\_  
 Date: \_\_\_\_\_ Time: \_\_\_\_\_ Site conditions: \_\_\_\_\_

Inspection Frequency Key: A=annual (required); M=monthly (recommended); S=after major storms (recommended)

Inspection Items	Inspection Frequency	Inspected? (Yes/No)	Maintenance Needed? (Yes/No)	Comments/Description
<b>Debris Removal</b>				
Adjacent area free of debris?	A/M			
Inlets and Outlets free of debris?	A/M			
Facility (internally) free of debris?	A/M			
<b>Vegetation</b>				
Surrounding area fully stabilized? (no evidence of eroding material into proprietary SCM)	A/M			
Grass mowed?	A/M			
<b>Water retention where required</b>				
Water holding chambers at normal pool?	A/M			
Evidence of erosion?				
<b>Sediment Deposition</b>				
Filtration Chamber free of sediments?	A			
Sedimentation and/or trash below manufacturer's recommended cleanout?	A			
<b>Structural Components</b>				
Any evidence of structural deterioration?	A			
Grates in good condition?	A			
Spalling or cracking of structural parts?	A			
<b>Outlet/Overflow Spillway</b>	A			
<b>Other</b>				
Noticeable odors?	A			
Any evidence of filter(s) clogging?	A/M			
Evidence of flow bypassing facility?	A			

Inspector Comments: \_\_\_\_\_  
 \_\_\_\_\_

Overall Condition of Facility:  Acceptable  Unacceptable

If any of the above Inspection Items are checked "Yes" for "Maintenance Needed," list Maintenance actions and their completion dates below:

Maintenance Action Needed	Due Date

The next routine inspection is scheduled for approximately: \_\_\_\_\_  
(Date)

Inspected by: (signature) \_\_\_\_\_

Inspected by: (printed) \_\_\_\_\_

### Stormwater Pond Inspections and Maintenance Checklist

Site Name: \_\_\_\_\_ Owner Change since last inspection? Y N

Location: \_\_\_\_\_

Owner Name: \_\_\_\_\_

Address \_\_\_\_\_ Phone Number \_\_\_\_\_

Site Status: \_\_\_\_\_

Date: \_\_\_\_\_ Time: \_\_\_\_\_ Site conditions: \_\_\_\_\_  
 Stormwater Pond Type:    Wet Pond     Wet ED Pond     Micropool Pond     Multiple Pond System   
    Dry Pond

*Inspection Frequency Key: A=annual (required); M=monthly (recommended); S=after major storms (recommended)*

Inspection Items	Inspection Frequency	Inspected? (Yes/No)	Maintenance Needed? (Yes/No)	Comments/Description
<b>Embankment and Emergency Spillway</b>				
Vegetation healthy?	A/S			
Erosion on embankment?	A/S			
Animal burrows in embankment?	A/S			
Cracking, sliding, bulging of dam?	A/S			
Drains blocked or not functioning?	A/S			
Leaks or seeps on embankment?	A/S			
Slope protection failure functional?	A/S			
Emergency spillway obstructed?	A/S			
Erosion in/around emergency spillway?	A/S			
Other (describe)	A/S			
<b>Riser and Principal Spillway</b>				(Describe type: concrete pipe, slotted weir, channel, etc.)
Low-flow orifice functional?	A/S			
Trash rack (Debris removal needed? Corrosion noted?)	A/S			
Sediment buildup in riser?	A			
Concrete/masonry condition (Cracks or displacement? Spalling?)	A			
Metal pipe in good condition?	A			
Control valve operation?	A			
Pond drain valve operation?	A			
Outfall channels function, not eroding?	A			
Other (describe)	A			
<b>Sediment Forebays</b>				
Sedimentation description				
Sediment cleanout needed (over 50 Percent full)?	A/S			
<b>Permanent Pool Areas (if applicable)</b>				

Undesirable vegetation growth?	A/M			
Visible pollution?	A/M			
Shoreline erosion?	A/M			
Erosion at outfalls into pond?	A/M			
Headwalls and end walls in good condition?	A/M			
Encroachment into pond or easement area by other activities?	A/M			
Evidence of sediment accumulation?	A			
<b>Dry Pond Areas (if applicable)</b>				
Vegetation adequate?	A/M			
Undesirable vegetation or woody plant growth?	A/M			
Excessive sedimentation?	A			
<b>Hazards</b>				
Have there been complaints from residents?	A/M			
Public hazards noted?	A/M			

Inspector Comments: \_\_\_\_\_  
 \_\_\_\_\_

**Overall Condition of Facility:**  Acceptable  Unacceptable

If any of the above Inspection Items are checked "Yes" for "Maintenance Needed," list Maintenance actions and their completion dates below:

Maintenance Action Needed	Due Date

The next routine inspection is scheduled for approximately: \_\_\_\_\_  
 (Date)

**Inspected by: (signature)** \_\_\_\_\_

**Inspected by: (printed)** \_\_\_\_\_

### Water Quality Swale Inspections and Maintenance Checklist

Site Name: \_\_\_\_\_ Owner Change since last inspection? Y N

Location: \_\_\_\_\_

Owner Name: \_\_\_\_\_

Address \_\_\_\_\_ Phone Number \_\_\_\_\_

Site Status: \_\_\_\_\_

Date: \_\_\_\_\_ Time: \_\_\_\_\_ Site conditions: \_\_\_\_\_

Inspection Frequency Key: A=annual (required); M=monthly (recommended); S=after major storms (recommended)

Inspection Items	Inspection Frequency	Inspected? (Yes/No)	Maintenance Needed? (Yes/No)	Comments/Description
<b>Debris Removal</b>				
Facility and adjacent area free of debris?	A/M			
Inlets and outlets free of debris?	A/M			
Any dumping of yard wastes into facility?	A/M			
Litter (branches) removed?	A/M			
<b>Vegetation</b>				
Surrounding area fully stabilized? (no evidence of eroding material into swale)	M			
Soil media is adequately covering (18 inches) choker stone layer below?	A/M			
Grass mowed?	A/M			
Plant height not less than design water depth?	A/M			
Fertilized per specifications?	A/M			
Plant composition according to approved plan?	A/M			
Unauthorized or inappropriate plantings?	A			
Plants healthy? (no diseased or dying vegetation)	A/M			
Evidence of plants stressed from inadequate watering?	A/M			
<b>Filtration Capacity</b>				
Clogging from oil or grease?	A/M			
Facility dewater between storms?	A/M			
Underdrain functioning properly?	A/M			
<b>Check Dams and Energy Dissipaters/Sumps</b>				
Any evidence of sedimentation buildup?	A/S			
Are sumps greater than 50% full of sediment?	A/S			
Any evidence of erosion and downstream toe of drop structures?	A/S			
<b>Sediment Deposition</b>				
Swale clean of sediments?	A			

Sediment not > 20% of swale design depth?	A			
<b>Outlet/Overflow Spillway</b>				
In good condition?	A			
Any evidence of erosion?	A			
Any evidence of blockages?	A			
Has facility been filled or blocked inappropriately?	A			
<b>Hazards</b>				
Have there been complaints from residents?	A/M			
Public hazards noted?	A/M			
Maintenance accesses free of hazards and fully operational?	A/M			

Inspector Comments: \_\_\_\_\_

\_\_\_\_\_

Overall Condition of Facility:  Acceptable  Unacceptable

If any of the above Inspection Items are checked "Yes" for "Maintenance Needed," list Maintenance actions and their completion dates below:

Maintenance Action Needed	Due Date

The next routine inspection is scheduled for approximately: \_\_\_\_\_

(Date)

Inspected by: (signature) \_\_\_\_\_

Inspected by: (printed) \_\_\_\_\_

## Appendix 2 – Contacts

Montgomery County Building & Codes - Stormwater  
350 Pageant Lane, Suite 309  
Clarksville, TN 37040  
(931) 648-5718  
<https://mcgtn.org/stormwater>  
[jhdoss@mcgtn.net](mailto:jhdoss@mcgtn.net)

Tennessee Department of Environment and Conservation  
Nashville Environmental Field Office  
711 R.S. Gass Blvd  
Nashville, TN 37216  
Phone: (615) 687-7000  
FAX: (615) 687-7078  
<https://www.tn.gov/environment/permit-permits/water/permits1/npdes-permits.html>

Household Hazardous Waste Information  
BiCounty Solid Waste Management  
3212 Dover Road  
Woodlawn, TN 37191  
(931) 648-5751  
<https://mcgtn.org/bi-county>

Native plant information:

*Landscaping with Native Plants:* <https://www.se-eppc.org/pubs/middle.pdf>

Tennessee Native Plant Society: <https://www.tnps.org/>



## **Appendix 3 – References & Credits**

Technical Guidance:

Montgomery County Stormwater Management Manual  
<https://mcgtn.org/stormwater/stormwater-management-program>

Nashville Stormwater Management Manual  
<https://www.nashville.gov/departments/water/developers/stormwater-review/stormwater-management-manual>

Knox County Stormwater Compliance Program  
<https://www.knoxcounty.org/stormwater/dev-manual-ordinance.php>

**Appendix 4 – Stormwater Inspection & Maintenance Agreement**



## Montgomery County, Tennessee

### INSPECTION & MAINTENANCE AGREEMENT

Plan Name: \_\_\_\_\_ Permit No. \_\_\_\_\_

Map: \_\_\_\_\_ Group: \_\_\_\_\_ Parcel: \_\_\_\_\_

Deed Book Volume: \_\_\_\_\_ Page No.: \_\_\_\_\_

Project Address:

Landowner(s):

Landowner's Address:

City: Clarksville State: TN Zip Code: \_\_\_\_\_

#### WITNESSETH

WHEREAS, Montgomery County, Tennessee ("the County") is required by federal and state surface water quality regulations and its National Pollutant Discharge Elimination System (NPDES) permit to prevent surface water quality degradation from development or redevelopment activities within its jurisdiction, and the County has adopted stormwater quality regulations as required and such regulations are contained in the County Stormwater Management Resolution; and

WHEREAS, Resolution No. 24-2-2 was adopted February 12, 2024 by the Montgomery County Commission, and under said resolution the Building Commissioner shall have the authority to inspect private drainage systems within the County, and to order such corrective actions to said private storm water drainage systems as are necessary to maintain properly the drainage systems within the County; and

WHEREAS, under said resolution it is provided that private storm water drainage systems must be maintained by the property Landowner, and a maintenance agreement must be executed before the development plan is approved; and

WHEREAS, the Landowner is the owner of certain real property identified above; and

WHEREAS, the Landowner is proceeding to build on and develop the property; and

WHEREAS, Site/Subdivision Plan \_\_\_\_\_, prepared by \_\_\_\_\_ dated \_\_\_\_\_, on file at the Montgomery County Building and Codes Department (hereinafter called the "Plan"), which is expressly made a part hereof, as approved or to be approved by the Montgomery County Building and Codes Department, provides for the construction of storm water drainage systems; and

WHEREAS, the County and the Landowner agree that the health, safety, and general welfare of the residents of Montgomery County require that storm water drainage systems be constructed and maintained on the property; and

WHEREAS, the County requires that stormwater drainage systems as shown on the Plan be constructed and adequately maintained by the Landowners;

NOW, THEREFORE, in consideration of the foregoing premises, the mutual covenants contained herein, and the following terms and conditions, the parties hereto agree as follows:

1. The stormwater control measures and stormwater drainage systems shall be constructed by the Landowner in accordance with the plans and specifications in the Plan.
2. The Landowner shall provide adequate long term maintenance and continuation of the stormwater control measures described in the Plan, to ensure that all stormwater facilities are and remain in proper working condition acceptable to the County. The Landowner shall perform inspection and preventative maintenance activities in accord with the Plan and the County's NPDES Permit and Stormwater Regulations and policies. The minimum maintenance and repair needs include but are not limited to: the removal of silt, litter and other debris, the cutting of grass, cutting and vegetation removal, and the replacement of landscape vegetation, in detention and retention basins, and inlets and drainage pipes and any other stormwater facilities.
3. The Landowner shall maintain a record of inspections and maintenance actions required by the Plan. The Landowner shall document the times of inspections, remedial actions taken to repair, modify or reconstruct the system, the state of control measures, and notification of any planned change in responsibility for the system. The County may require that the Landowner's records be submitted to the County.
4. If it is later determined that the County's NPDES permit clearly directs Landowners or the County to manage stormwater treatment systems differently than specified in the Plan, the direction of the NPDES permit shall override the provisions of the Plan.
5. The Landowner hereby grants to the County the right of ingress, egress and access to enter the Property for the purpose of inspecting, operating, installing, constructing, reconstructing, maintaining or repairing the facilities. The Landowner hereby grants to the County the right to install and maintain equipment to monitor or test the performance of the stormwater control system for quality and quantity upon reasonable notice to Landowner.
6. If the Landowner fails to maintain or repair the stormwater control measures as required by the Montgomery County Stormwater Regulations and Policies within the prescribed schedule set by the County, the County shall perform the maintenance and repair at its expense.
7. In the event the County, pursuant to this Agreement, performs work of any nature, or expends any funds in performance of said work for labor, use of equipment, supplies, or materials, the Landowner shall reimburse the County on demand, within a time frame specified by the County for all costs incurred, including reasonable administrative costs and attorney's fees in the event that an action to collect such costs must be instituted. If the landowner fails to reimburse the County for the cost of

maintenance or repair, the County's cost of performing the maintenance shall be a lien against the property.

8. The Landowner and the Landowner's heirs, administrators, executors, assigns, and any other successor in interest shall indemnify and hold the County harmless from any and all damages, accidents, casualties, occurrences, claims or attorney's fees which might arise or be asserted, in whole or in part, against the County from the construction, presence, existence, or maintenance of the stormwater control facilities subject to the Plan and this Agreement. In the event a claim is asserted against the County, its officers, agents or employees, the County shall notify the Landowner, who shall defend at Landowner's expense any suit or other claim. If any judgment or claims against the County shall be allowed, the Landowner shall pay all costs and expenses in connection therewith. The County will not indemnify, defend or hold harmless in any fashion the Landowner from any claims arising from any failure, regardless of any language in any attachment of other document that the Landowner may provide.
9. No waiver of any provision of this Agreement shall affect the right of any party thereafter to enforce such provision or to exercise any right or remedy available to it in the event of any other default.
10. The Landowner shall have the facilities inspected in accordance with the County's stormwater resolution and adopted policies, and certify to the County that the constructed facilities conform and purport substantially to the approved Plan. If the constructed condition of the facility or its performance varies significantly from the approved Plan as determined by the County, appropriately revised calculations shall be provided to the County and the Plan shall be amended accordingly.
11. Landowner agrees that the failure to follow the provisions and requirements of the Plan may result in the revocation of previously approved credits to stormwater user fees, or the imposition of such stormwater user fees or of additional stormwater user fees.
12. The Landowner agrees that for any systems to be maintained by a property Landowner's association, deed restrictions and covenants for the subdivision or other development will include mandatory membership in the Landowner's association. Landowner's association responsible for providing maintenance of the system, will require the association to maintain the stormwater system, will prohibit termination of this covenant by unilateral action of the association, and provide for unpaid dues or assessments to constitute a lien upon the property of a Landowner upon recording a notice of non-payment.
13. This Agreement shall be recorded among the land records of Montgomery County, Tennessee, and shall constitute a covenant running with the land, and shall be binding on the Landowner, its administrators, executors, assigns, heirs, and any other successors in interest.

WITNESS the following signatures and seals:

By \_\_\_\_\_  
Landowner or Authorized Agent  
  
\_\_\_\_\_  
Name (Print)

By \_\_\_\_\_  
Building and Codes Department  
John H Doss  
Montgomery County  
Stormwater Coordinator

STATE OF TENNESSEE                    )  
COUNTY OF MONTGOMERY    )

\_\_\_\_\_ personally  
appeared before me, a States of Tennessee Notary Public for the said state and county and affirmed the  
information and executed the instrument here in above for the purposes contained therein.

This the \_\_\_\_\_ day of \_\_\_\_\_, 2024

\_\_\_\_\_  
Notary Public

My commission expires: \_\_\_\_\_

Prepared by: \_\_\_\_\_  
**John H Doss**  
**Montgomery County Stormwater Department**  
**350 Pageant Lane, Suite 309**  
**Clarksville, TN 37040**

## STORMWATER SCM MAINTENANCE GUIDELINES

The required maintenance interval for stormwater control measures (SCMs) are often dependent upon the degree of pollutant loading from a particular drainage basin. SCM maintenance can best be broken into three categories: **inspection, routine maintenance, and major maintenance**.

Though each SCM type has its own unique characteristics, **inspections** will generally consist of an assessment to assure its functionality and the general condition.

**Routine maintenance** will generally consist of trash and vegetation removal, unclogging of drains, minor sediment removal and exchange of filter media where applicable.

**Major maintenance** will be completed as required from inspections and generally consists of **significant reconstruction due to failures** in the SCM. Examples of major maintenance include dredging, excavation, removal of existing media, replacing fabric, replacing the under-drain, and reestablishment of vegetation.

The following schedule is offered as a guideline for performing **inspection and routine maintenance** for a range of SCM categories.

SCM	Inspection Frequency	Routine Maintenance Frequency
<b>Inspection Frequency key:</b> A = Annual; M=Monthly; S=After Major Storms; Q=Quarterly; SA=Semi Annually		
Bio-retention Systems	A, S	2 x /year
Cartridge or Module Media Filtration Structures	SA	1 – 2 x /year
Catch Basin Inserts (long term)	Q	3 – 4 x /year
Dry Pond	M	3 – 4 x /year
Dry Wells	A	1 x /year
Filter Strips or Swales	M	2 – 3 x /year
Green Roofs	SA; S	2 – 3 x /year
Hydrodynamic or Gravity Separators	SA	1 – 2 x /year
Infiltration Trenches	A; S	2 – 3 x /year
Permeable Pavement	A	2 – 3 x /year
Rainwater Gardens	SA; S	2 – 3 x /year
Rainwater Harvesting	SA; S	2 – 3 x /year
Sand Filter	Q first year; SA after	1 – 2 x/ year
Trash & Debris Screens	SA; S	2 – 3 x /year
Underground Storage Facilities	SA	1 x /year
Wetlands	SA	2 x /year
Wet Pond	Q	2 – 3 x /year
Headwalls	A	1x/ year
Injection Well	Q	3 – 4 x /year

All SCMs must be inspected and certified by a licensed engineer, landscape architect, or other qualified professional familiar with applicable SCM design and maintenance requirements every 5 years. Questions about SCM maintenance and repair can be directed to the Office of the Stormwater Coordinator.

For more information and inspection sheets go to: <https://mcgtn.org/stormwater/best-practices> and review the **Citizens Guide for Maintenance of Stormwater Control Measures.**