



## **BUILDING AND CODES DEPARTMENT**

Phone  
931-648-5718

350 Pageant Lane Suite 309  
Clarksville, TN 37040

Fax  
931-553-5121

### **Montgomery County Off-Site Stormwater Mitigation Policy**

Authority: NPDES General Permit for Discharges from Small Municipal Separate Storm Sewer Systems; Montgomery County, TN Stormwater Regulations.

Off-site stormwater mitigation may be used when approved by the Montgomery County Building Commissioner. The off-site facility must:

1. Treat a minimum of 1.5 times the required Water Quality Treatment Volume;
2. Be located within the same USGS 12 digit hydrologic unit code watershed as the site providing the runoff;
3. Be designed and constructed in accordance with Montgomery County Stormwater Regulation Best Management Practices;
4. Be shown by appropriate engineering study that the proposed off-site facility does not impair attainment of the Montgomery County Stormwater Regulatory requirements;
5. Not cause downstream damages as defined in the Montgomery County Stormwater Regulations.

Sites using off-site facility must pre-treat any discharges so there is an 80% Total Suspended Solids (TSS) reduction prior to reaching the off-site facility.